

APPENDIX D

Proposed Restricted Substances

Parameters	Restricted Substances, Allowable Concentrations (mg/L)		
	2016	2017	2018
1,1,2,2-tetrachloroethane	-	-	0.06
1,2-dichlorobenzene	-	-	0.1
Aluminum	-	-	50
Arsenic	-	-	1
Benzene	1	1	0.55
Cadmium	4	4	0.7
Chloroform	-	-	0.2
Chromium (total)	5	5	2.8
Cobalt	-	-	5
Copper	4	4	2
Cyanide	3	3	1.2
Ethyl Benzene	1	1	0.12
Hexachlorobenzene	-	-	0.055
Lead	5	5	0.7
Mercury	-	-	0.01
Methyl chloride	-	-	0.1
Molybdenum	-	-	5
Nickel	5	5	2
Phenolics	0.1	0.1	0.1
PCBs	-	-	0.004
Selenium	-	-	0.8
Silver	-	-	0.4
Sulphide	3	3	3
Sulphate	-	-	1000
Tetrachloroethylene	-	-	0.06
Toluene	1	1	0.1
Trichloroethylene	-	-	0.06
Xylenes	1	1	0.4
Zinc	5	5	2